सत्यमेव जयते

Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
6,Diamond Harbour Road, Silpara, Kol-700008

Memo No.: FSR/IND/WB/FES/20182019/17035 **Date : 05-05-2025**

From :
Divisional Fire Officer
South 24 Parganas Division,
West Bengal Fire & Emergency Services

To :
Annie Besant Day School
Mouza-Mohanpur, Vill.-Parulia, P.S.-Diamond Harbour, Dist.-South 24 Parganas, Pin-743368

Memo No.: FSR/IND/WB/FES/20182019/17035

Sub : Renewal of Fire Safety Certificate for a G+2 storied under group Educational Occupancy in the name & style of "Annie Besant Day School" which laid at the premises of Mouza-Mohanpur, Vill.-Parulia, P.S.-Diamond Harbour, Dist.-South 24 Parganas, Pin-743368.

This is in reference to your AIN 211912506300004784 dated 16-Apr-2025 regarding Renewal of Fire Safety Certificate for a G+2 storied under group Educational Occupancy in the name & style of "Annie Besant Day School" which laid at the premises of Mouza-Mohanpur, Vill.-Parulia, P.S.-Diamond Harbour, Dist.-South 24 Parganas, Pin-743368..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

Recommendation:

1. Driveway must be free from any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the driveway.
2. The interior finish decoration of the building shall be with low flame spread material confirming I.S. specification.

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912506300004784

3. To eliminate risk of Fire hazards, good housekeeping both for inside and outside of the building shall be strictly maintained.
4. Existing electrical wiring of the whole building shall have to be carefully checked for wear and tear in them, particularly lines above false ceiling.
5. The notice of Fire fighting and evacuation from the building shall be prepared and displayed at all vulnerable place of the building.
6. The employees and security staff shall be conversant with installed Firefighting equipments of the building and to operate in the event of Fire and testing.
7. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
8. Electrical switch gear room shall be protected with automatic CO2 or D.C.P Fire extinguisher confirming I.S. specification.
9. First aid firefighting system shall be provided as per I.S. specification.
10. Arrangement shall have to be made for regular checking, testing and maintenance of all the Firefighting installation in the building to keep them in perfectly good working condition at all the times.
11. If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. Conduits pipes continuously bonded with earth.
12. Periodical flashing of water from the fire water pipe line shall be made to maintain efficient working performance of above mentioned system.
13. This Renewal of Fire Safety Certificate is valid for 03(Three) years and have to be renewed after three years from the date of issue of this certificate.

*Mandatory Note:
The third stair to be constructed at the mark place within 03 months from the date of issue of this certificate, otherwise the certificate to be treated as cancelled.

Valid Upto : 03-May-2028

Memo No.:
FSR/IND/WB/FES/20182019/17035

Signature valid

Digitally Signed.
Name: SHYAM CHANDRA MONDAL
Date: 05-May-2025 13:08:01
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912506300004784